# **ABK-21**

## ANCHOR BRACKET KIT INSTRUCTIONS

## **Attention Installing Personnel**

As a professional installer, you have an obligation to know the product better than the customer. This includes all safety precautions and related items.

Prior to actual installation, thoroughly familiarize yourself with this Instruction Manual. Pay special attention to all safety warnings. Often during installation or repair, it is possible to place yourself in a position which is more hazardous than when the unit is in operation.

Remember, it is **your** responsibility to install the product safely and to know it well enough to be able to instruct a customer in its safe use.

Safety is a matter of common sense...a matter of thinking before acting. Most dealers have a list of specific good safety practices...follow them.

The precautions listed in this Installation Manual are intended as supplemental to existing practices. However, if there is a direct conflict between existing practices and the content of this manual, the precautions listed here take precedence.

## Description

This anchor bracket is for use with condensers and heat pumps. The anchor bracket can be installed without accessing the inside of the unit. Consult the product specifications applicable to your model.

**NOTE:** Please contact your distributor or our website for the applicable product specifications referred to in this manual.



### HIGH VOLTAGE:

DISCONNECT ALL POWER BEFORE SERVICING OR INSTALLING THIS UNIT. MULTIPLE POWER SOURCES MAY BE PRESENT. FAILURE TO DO SO MAY CAUSE PROPERTY DAMAGE, PERSONAL INJURY OR DEATH.



#### **Kit Contents**


- Installation Instructions x 5
- Anchor Bracket x 20

### Installation Instructions

- 1. Disconnect all electrical power.
- 2. Insert an anchor bracket in each of the four (4) slots on the underside of the basepan, one on each side.

**NOTE:** These slots are the same slots utilized by the hold down bracket during shipment.

When the anchor bracket is engaged in the slots, pull the bracket outwards and swing down to lock the bracket in place.



- 4. Attach the anchor brackets to the pad, using either ¼" diameter Tapcon® concrete screws or similar self-tapping concrete screws. The minimum screw length should be 1-¼". Two screws are required for each bracket. Follow manufacturer's instructions for installing screws.
- 5. Reconnect the electrical power.

NOTE: SPECIFICATIONS AND PERFORMANCE DATA LISTED HEREIN ARE SUBJECT TO CHANGE WITHOUT NOTICE

Visit our website at

www.daikincomfort.com, www.goodmanmfg.com or www.amana-hac.com for information on:

IO-772A 12/2013

Products

Warranties

Customer Services

• Parts

• Contractor Programs and Training

• Financing Options

© 2011, 2013 Goodman Manufacturing Company, L.P.



